



SGS

EC Type Examination Certificate Number: 0120/SGS0211

Shenzhen Clou Electronics Co., Ltd.

16/F, Clou Building
Baoshen Road South
Hi-tech Industrial Park North
Nanshan District
Shenzhen, China

Instrument Identification:
CL730D22L

Instrument Traceable Number
0120/SGS0211

Poly phase, Active Import/Export (kWh), Transformer Operated, Electricity Meter

has been assessed and certified as meeting the requirements of

EC Directive 2004/22/EC

Measuring Instruments Annex B

It is certified that the manufacturer's technical design and specimen for the above instrument has been examined and, based on the evidence submitted, it is considered that the instrument conforms to the requirements of

MI-003 of EC Directive 2004/22/EC

This certificate must be used in conjunction with a certificate covering the product verification as required in Annex D or Annex F.

This certificate is valid for 10 years from 15th April 2016 until 14th April 2026
Issue 1

Certification is based on report number(s) SZES151000342101 dated 15th April 2016

Authorised Signature

Jan Saundérs

SGS United Kingdom Limited, Notified Body 0120
Unit 202B Worle Parkway, Weston-super-Mare, BS22 6WA UK
t +44 (0)1934 522917 f +44 (0)1934 522137 www.sgs.com

SGS United Kingdom Ltd, Units 12A & 12B, South Industrial Estate, Bowburn, Durham, DH6 5AD UK
t +44 (0)191 377 2000 f +44 (0)191 377 2020 www.sgs.com



This document is issued, on the Client's behalf, by the Company under its General Conditions of Service printed overleaf. The Client's attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein.

Any other holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Clients instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents.


MID-B06E Rev 7

Page 1 of 8

SGSPAPER
15084942


EC Type Examination Cert



	EC-Type Examination Certificate Number:	
	0120/ SGS0211	
	Issue Number:	Dated: 15 th April 2016

1. Technical Data


Manufacturer	Shenzhen Clou Electronics Co. Ltd.
Meter Type	CL730D22L
Voltage Rating (U_n)	3 x 220/380V ... 3 x 240/415V
Current Rating ($I_{min} - I_{ref} (I_{max})$)	0.01-1(10)A
Frequency (F_n)	50/60Hz
Active Accuracy Class (kWh)	C (kWh)
Type of circuit	3p4w
Temperature Range	-40°C to +70°C
Software/ Firmware Version No Identification Location	01 LCD
Bill Of Materials Number	26064840000001
IP Rating	IP54
Insulation Protective Class	Class II
LED Pulse Constant	6400 imp/ kWh
Impulse Voltage Rating	6kV
AC Voltage Rating	4kV
Main Cover Sealing Type	Wire & Crimp
Integrity of meter	Inaccessible without breaking seals
Intended Location of the Meter	Outdoor
Type of Register	LCD
Terminal Arrangement(s)	BS

	EC-Type Examination Certificate Number:	
	0120/ SGS0211	
	Issue Number:	Dated: 15 th April 2016

2. Photograph of Meter and Sealing Plan





Main cover seals




	EC-Type Examination Certificate Number:	
	0120/ SGS0211	
	Issue Number:	Dated: 15 th April 2016

3. Nameplates

GPRS Version



▲ Class C ▲ ② ▲  ▲ 
 6400 imp/kWh 6400 imp/kvarh Warning Credit

2G LINK

 **M160120**
SGS0211
 
 CLOU ELECTRONICS

CL730D22L

Three Phase Electronic Energy Meter



3x220/380 V ... 3x240/415 V 0.01-1(10)A 50 Hz IP54  

IEC 62052-11 IEC 62053-22 IEC 62053-23




EN 50470-1 EN 50470-3 -40°C~70°C

Made in China 2015

PLC Version



▲ Class C ▲ ② ▲  ▲ 
 6400 imp/kWh 6400 imp/kvarh Warning Credit

RXD TXD

 **M160120**
SGS0211
 
 CLOU ELECTRONICS

CL730D22L

Three Phase Electronic Energy Meter

3x220/380 V ... 3x240/415 V 0.01-1(10)A 50 Hz IP54  

IEC 62052-11 IEC 62053-22 IEC 62053-23

EN 50470-1 EN 50470-3 -40°C~70°C

Made in China 2015

EC-Type Examination Certificate Number:

0120/ SGS0211

Issue Number:

Dated: 15th April 2016

RF Version

▲ Class C 6400 imp/kWh ▲ ② 6400 imp/kvarh ▲ Warning ▲ Credit

LINK ACT

CE M16 0120

SGS0211

CLOU ELECTRONICS

CL730D22L

Three Phase Electronic Energy Meter

3x220/380 V ... 3x240/415 V 0.01-1(10) A 50 Hz IP54

IEC 62052-11 IEC 62053-22 IEC 62053-23

EN 50470-1 EN 50470-3 -40°C~70°C

Made in China 2015



EC-Type Examination Certificate Number:


0120/ SGS0211

Issue Number:

Dated: 15th April 2016

4. Influence factors for temperature, frequency and voltage

		Influence Factors for temperature, frequency and voltage							
Current	PF Cos	-40	-25	-10	5	30	40	55	70
I _{min}	1.0	0.36	0.46	0.33	0.32	0.32	0.32	0.32	0.32
I _{tr}	1.0	0.27	0.31	0.21	0.20	0.20	0.20	0.21	0.20
10I _{tr}	1.0	0.22	0.25	0.17	0.17	0.17	0.17	0.17	0.17
I _{max}	1.0	0.23	0.25	0.17	0.16	0.16	0.16	0.16	0.16
I _{tr}	0.5ind	0.26	0.26	0.23	0.23	0.23	0.23	0.23	0.23
10I _{tr}	0.5ind	0.25	0.24	0.20	0.20	0.21	0.20	0.21	0.20
I _{max}	0.5ind	0.37	0.37	0.35	0.35	0.35	0.34	0.35	0.35
I _{tr}	0.8cap	0.43	0.52	0.43	0.43	0.43	0.43	0.43	0.43
10I _{tr}	0.8cap	0.24	0.24	0.19	0.19	0.19	0.19	0.19	0.19
I _{max}	0.8cap	0.15	0.15	0.08	0.08	0.08	0.08	0.08	0.08
L1									
I _{tr}	1.0	0.29	0.28	0.25	0.25	0.25	0.25	0.25	0.25
10I _{tr}	1.0	0.25	0.25	0.21	0.20	0.20	0.20	0.20	0.20
I _{max}	1.0	0.23	0.23	0.19	0.19	0.19	0.19	0.19	0.19
I _{tr}	0.5ind	0.33	0.32	0.29	0.29	0.29	0.29	0.29	0.29
10I _{tr}	0.5ind	0.18	0.21	0.17	0.17	0.17	0.17	0.17	0.17
I _{max}	0.5ind	0.29	0.31	0.28	0.28	0.28	0.28	0.28	0.28
L2									
I _{tr}	1.0	0.28	0.28	0.25	0.25	0.25	0.25	0.25	0.25
10I _{tr}	1.0	0.24	0.23	0.21	0.21	0.21	0.21	0.21	0.21
I _{max}	1.0	0.23	0.23	0.20	0.21	0.20	0.20	0.20	0.20
I _{tr}	0.5ind	0.16	0.15	0.12	0.12	0.12	0.11	0.11	0.11
10I _{tr}	0.5ind	0.23	0.23	0.22	0.22	0.22	0.26	0.29	0.22
I _{max}	0.5ind	0.42	0.42	0.40	0.40	0.40	0.40	0.40	0.40
L3									
I _{tr}	1.0	0.17	0.16	0.13	0.13	0.13	0.13	0.13	0.13
10I _{tr}	1.0	0.15	0.14	0.10	0.11	0.10	0.10	0.10	0.10
I _{max}	1.0	0.14	0.13	0.08	0.09	0.08	0.08	0.08	0.08
I _{tr}	0.5ind	0.25	0.24	0.24	0.23	0.23	0.24	0.24	0.24
10I _{tr}	0.5ind	0.24	0.24	0.24	0.23	0.23	0.23	0.23	0.23
I _{max}	0.5ind	0.43	0.43	0.43	0.43	0.19	0.44	0.43	0.43

	EC-Type Examination Certificate Number:	
	0120/ SGS0211	
	Issue Number:	Dated: 15 th April 2016

During the type approval examination the influence factors for temperature, frequency and voltage are determined per load point. The table above represents the sum of the square values per load, determined via the following formula:-


$$\delta e (T, U, f) = \sqrt{(\delta e^2 (T, I, \cos\phi) + \delta e^2 (U, I, \cos\phi) + \delta e^2 (f, I, \cos\phi))}$$

where

$\delta e(T, I, \cos\phi) =$ Additional error due to variation of the temperature at the same load

$\delta e(U, I, \cos\phi) =$ Additional error due to variation of the voltage at the same load

$\delta e(f, I, \cos\phi) =$ Additional error due to variation of the frequency at the same load

	EC-Type Examination Certificate Number:	
	0120/ SGS0211	
	Issue Number:	Dated: 15 th April 2016

5. Annex of Variants

Product Variant Identification Details:

Type Designation	Description of meter
CL730D22L	3 x 220/380V ... 3 x 240/415V 0.01-1(10)A. 3p4w. Transformer operated Optional detachable communication module: GMS/GPRS modem, PLC modem, RF modem

Modifications to the meter(s) described according to approval No. **0120/ SGS0211** must be notified to the issuing body to confirm the meter(s) continuing compliance to the relevant pattern approval standard(s).

6. Document Revision History

Issue	Date	Comments
1	15/04/2016	Initial Issue